ALLIED ENGINEERING PUBLICATION

PRESSURE MEASUREMENT BY CRUSHER GAUGES NATO APPROVATES S EGREGIES GAUGES

SEPTEMBER 1991

(i)

AEP-23

ALLIED ENGINEERING PUBLICATION

NATO ARMY ARMAMENTS GROUP
SURFACE-TO-SURFACE ARTILLERY PANEL

PRESSURE MEASUREMENT BY CRUSHER GAUGES
NATO APPROVAL TESTS FOR CRUSHER GAUGES

09/91



(ii)

AEP-23

NORTH ATLANTIC TREATY ORGANIZATION

MILITARY AGENCY FOR STANDARDIZATION (MAS)

NATO LETTER OF PROMULGATION

September 1991

- 1. AEP-23, Pressure Measurement by Crusher Gauges NATO Approval Tests for Crusher Gauges, is a NATO UNCLASSIFIED publication. The agreement whereby nations have undertaken to use this publication is recorded in STANAG 4113.
 - 2. AEP-23 is effective upon receipt.
- 3. AEP-23 contains only practical information. As any corrections that the nations concerned may make to it are not subject to ratification they will be promulgated upon receipt.

E. STAI Major-General, NOAF Chairman, MAS

(iii)

AEP-23

RECORD OF CHANGES

Change Date	Date Entered	Effective Date	By Whom Entered
1 2 3			

(iv) <u>AEP-23</u>

	CONTENTS	Page No.
PART	<u>I</u>	1
	NATO APPROVED CRUSHER GAUGES	,
	Chapter 1: General Chapter 2: Characteristics of each approved type	2· 9
PART	<u>11</u>	10
	INSTRUCTIONS FOR USE OF CRUSHER GAUGES	
PART	III	12
	CRUSHER SPECIFICATIONS	
PART	IV	15
	PROCEDURE FOR SUBMISSION OF CRUSHER GAUGES FOR NATO APPROVAL	
	Chapter 1: Acceptance procedure and criteria Chapter 2: Definition of terms relating to quality of measurements	16 17
	Chapter 3: Dynamic firing tests of crusher gauges Chapter 4: Analysis of results	18 21
PART	· v	42

APPROVAL OF CRUSHER GAUGES

- 1 -

<u>AEP-23</u>

PART I

NATO APPROVED CRUSHER GAUGES

AEP-23

09/91

AEP-23

- 2

CHAPTER 1

GENERAL

A NATO approved crusher gauge is defined as the combination of gauge components and a crusher, for neither the gauge components nor the crusher can be used alone.

NATO approved crusher gauges are used to measure the maximum pressure developed in the chamber of a gun during the firing of a round. Crusher gauges are normally preferred to electrical gauges because crusher gauges are simpler to use. The crusher housed within the gauge body is plastically deformed by a piston subjected to the transient gas pressure. After firing, the remaining length of the crusher is measured and from this the applied pressure can be deduced.

A list of NATO approved crusher gauges is at Annex and detailed figures for each gauge, together with resulting limitations, are at Appendices 1 to 5.

, , ANNEX to CHAPTER I OF AEP-23

ANNEX I - NATO APPROVED CRUSHER GAUGES

United Kingdom MK8	Sphere - Lot N°1-85 " "Sphere - Lot N°8	4.763	۵ <u>۹</u>	
	" " Sphere - Lot N°8	: ±	9	see Appendix 1
	" Sphere - Lot N°8	r	Ξ.	z
	Sphere - Lot N°8		2	=
MK 9	-	4.763	d	see Appendix 2
	-	=	윺	=
Spain MT 26 BP Cy	Cylinder-Lot N° 05-90-C1-MT26	5×7	ď	see Appendix 3
MT 26 AP	=		셮	=
Germany/ Netherlands 31/701	Sphere - Lot N°90-91-01	9	a .	see Appendix 4
38/3.91		:	£	=
France	Cylinder - Lot N°1-90	3x4.9	LP and HP	see Appendix 5

Note: This Annex and the associated appendices are based on the results of the 1990 NATO comparative firings in Bourges.

APPENDIX 1 to	ANNEX to	AEP-23
	- 4 -	RANGES AND LIMITS - US

}	GAUGES: M11 (positive temperatures) and M12 (negative temperatures) Indicators of precision of the gauge F(X)	39 1.09 57 40 52 69 58 38 55 73 47 58 54 48 51 62 44 50 47 79 72	Temperature (degrees Celsius) Indicators of accuracy of the mean of the	2.99 1.53 50 4.21 1.96 96 2.96 1.03 1.38 1.94 2.04 1.75 1.17 1.41 1.13 54 87 1.50 1.09 1.82 1.22 64 89 82 86 83 97 57 51 57 65 88 1.21 1.08 41 70 1.27 1.03 1.17 1.00 76 1.15 1.31 1.48 83 1.05 1.24 66 -40 -33 -13 21 52 63
	GAUGES: M11 (positive temperatures) and M12 (negative temperatures) Indicators of precision of the	6500 1.48 1.01 6000 1.02 80 5200 1.04 49 4400 1.03 58 3700 84 65 2200 48 45 1700 87 73	Temperature tors of accuracy (5500 2.99 1.53 50 6000 2.96 1.03 1.38 5200 1.17 1.41 1.13 4400 1.09 1.82 1.22 3700 86 83 97 2900 65 88 1.21 2200 1.27 1.03 1.17 1700 1.31 1.48 83
		Pressure (bars)	Indica	gauge Pressure (bars)
:	of the gau	76 17 50 78 33 59 68 54 59 66 98 60 1.08 77	52 63 s Celstus)	73 33 56 82 57 59 1.16 68 82 69 93 62 1.17 70
	GAUGE: T 19 Indicators of precision of the gauge $F(X)$	1.28 38 83 64 38 51 66 46 49 85 1.08 59 1.55 77	Temperature (degrees Celsius) Indicators of accuracy of the mean of	(%) 86 1.26 43 76 1.34 61 56 46 72 78 81 50 1.27 73 1.17 1.51 1.69 66 1.51 1.52 66
	GAU dicators of F(X)	98 65 84 70 87 11.02 11.40	Temperat	1.03 86 0 69 76 0 93 56 0 1.69 1.27 0 1.29 1.21 0 2.23 1.51
		Pressure 2300 (bars) 2000 1700 1400 1100 800 500	Indicato	the gauge Pressure 2300 (bars) 2000 1700 11400 1100 800 500
	CRITERIA (F) and accuracy gauge.	2/2	0 +63 es Celstus)	
	ACCEPTANCE precision J) of the F/J	2/4	10mperature (degrees	
	STANDARD ACCEPTANCE CRITE Indicators of precision (F) a of the mean (J) of the gauge.	6500 Pressure (bars) 4000	Temperati	

 Values underlined are those that exceed the standard criteria.
 Panel IV (SP/2) may authorise 4% for F for pressures above 4000 bars at temperatures below -30C*. Motes:

Temperature (degrees Celsius)

Temperature (degrees Celsius)

NATO UCLASSIFIED

5294.A

- 17 -

٥
ш
_
4
_
S
S
⋖
_
ပ
_
z
_
_
0
_
⋖
z

APPENDIX 2 to ANNEX to CHAPTER 1 of AEP-23	of the g	1.44 70 50 1.03 35 39 81 58 60	71 35 62 45 54 60 67 24 51 42 50 83 60 59 66 61 58 52 41 82 56 70 49 51 52	-33 -13 21 52 63 Temperature (degrees Celsius)	indicators or accuracy or the mean of the gauge. J(%)	73 2.25 79 1.94 1.02 18 3.46 54 87 65 60 4.13 63 76 1.33 25 2.50 76 47 1.37 96 1.98 46 55 97 50 1.43 71 62 72 65 1.70 1.44 1.04 1.00 71 1.20 98 73 98 73 -13 21 52 63
	ndicator	6500 2.10 6000 89 5200 1.00	4400 3700 2200 1700		Indicators of a of the gauge.	6500 6.73 6000 5.18 5200 2.60 4400 1.25 3700 96 2900 1.50 2200 1.65 1700 1.71
RANGES AND LIMITS - UK	GAUGE: MK 8 Indicators of precision of the gauge I(%)	2300 3.05 2.37 1.03 52 77 1.02 Pressure 2000 2.48 2.18 70 83 88 58 (bars) 1700 1.67 1.07 63 58 71 61	1.37 63 51 56 36 42 69 59 53 50 47 45 60 62 60 62 47 63 68 61 70 49 67 45	33 -13 21 52 63 ture (degrees Celsius)	-	2300 6.10 2.78 2.08 1.23 2.12 1.79 Pressure 2000 3.48 2.91 1.95 1.05 95 98 (bars) 1700 2.36 1.12 1.61 61 76 95 1400 1.79 1.44 1.48 63 1.18 1.11 1100 1.38 1.17 1.11 91 47 57 800 96 2.61 70 1.31 1.04 1.09 500 2.77 96 89 95 1.04 73 -40 -33 -13 21 52 63
	STANDARD ACCEPTANCE CRITERIA Indicators of precision (F) and accuracy of the mean (J) of the gauge. F/J 6500	(bars) (2) Pressure (bars) 4000	2/2 1/2	Temperature (degrees Celsius)		Pressure (bars)

Notes:

Temperature (degree Celsius)

Temperature (degrees Celsius)

UCLASSIFIED NATO

Values underlined are those that exceed the standard criteria.
 Panel IV (SP/2) may authorise 4% for F for pressures above 4000 bars at temperatures below -30C*.

0
w
-
<u>.</u>
_
S
S
<
ပ
Z
_
0
-
~

Z

	·		
`	٠.	•	

APPENDIX 3 to ANNEX to CHAPTER 1 of AEP-23

RANGES AND LIMITS - SP

Indicators of precision of the gauge GAUGES: MT 26 -AP

Indicators of precision (F) and accuracy STANDARD ACCEPTANCE CRITERIA of the mean (J) of the gauge.

Indicators of precision of the gauge GAUGE: MT 26 - BP

(bars)

2/2

(2)

Pressure (bars)

400**4**

22

Indicators of accuracy of the mean of Temperature (degrees Celstus)

-63

ဓ္

9

500

1/2

2/2

Temperature (degrees Celsius)

ر لا لا

the gauge.

Pressure

(bars)

Indicators of accuracy of the mean of the gauge. J(X)

1.03 86 3,00 1.39 67 79 3 300 2.59 1.45 1.77 52 30 5.04 1.30 1.48 63 3 5.55 86 -33 9 5200 4400 3700 2900 2200 1700 Pressure (bars) 82 1.15 52 73 1.03 76 1.40 47 90 80 88 2 46 1.03 85 1.40 98 90 25 21 1.90 92 2.19 1.37 64 3.50 1.75 1.24 3.72 65 1.82 -13 56 1.29 83 2.67 -40 -33 45 3.11 2000 | 1.43 2300 1700 1400 1100 80

88 75 78 63 91

39 39 52

Temperature (degree Celsius)

Temperature (degrees Celsius)

25

≂

-13

82

81 1.01

63 1.05 62

> Panel IV (SP/2) may authorise 4% for F for pressures above 4000 bars at temperatures below -30C*. Values underlined are those that exceed the standard criteria.
> Panel IV (SP/2) may authorise 4% for F for pressures above 400 Notes:

UCLASSIFIED NATO

- 9 -

5294.A

_	,	١
4	_	
v	,	
<	c	
2	_	
=		ı
*	_	
•	Z	

ACCEPT recist of th of th (2) 2/4 2/4	NATO UNCLASSIFIED APPENDIX 4 to ANNEX to CHAPTER 1 of RANGES AND LIMITS - GE/NL	STANDARD ACCEPTANCE CRITERIA GAUGE: 31/701 Indicators of precision of the gauge Indicators of precision of the gauge of the gauge. F(χ) of the mean (3) of the gauge.	 2/2 (hare) 2000 41 38 50 49 30	1700 63 59 40 47 48 52 5200 72	.	31 54 60 55 87 54	1/2 800 67 55 1.01 46 80 43	500 74 75 1.00	:	10 -30 +63 -40 -33 -13 21 52 63 -40 -33 -13 21 52 63	Tamparature (Aparage Calcus)
		TANCE CRITER ton (F) and he gauge.									

Ę	92 49 1.34 77 77 57 84 84	63
e me	86 92 55 49 85 1.34 74 89 46 77 60 57 77 87	25
of th	57 57 57 57 57 57 57 57	77
uracy K)	1.36 1.77 1.68 1.41 85 62 74 74	-13
f acc	1.69 61 1.16 2.08 98 39 75	-33
ors o	1.59 1.46 1.76 69 99	-40
Indicators of accuracy of the mean of the gauge. $J(\Sigma)$	6500 6000 5200 4400 3700 2200 1700	
	Pressure 6500 1.69 1.36 2.41 86 95 (bars) 6000 61 1.77 1.20 55 46 5200 1.59 1.16 1.68 1.00 85 1.34 4400 1.46 2.08 1.41 57 74 85 3700 1.76 98 85 52 46 77 2200 69 39 62 74 60 57 2200 99 98 74 65 65 81 1700 76 75 1.93 72 77 81	
a of	64 38 52 94 67 72 1.20	
he mea	55 45 32 49 85 91 49 85 58 44 75 29 59 60 1.05 97 55 1.67 96 1.06 1.39 1	25
of t	55 45 32 49 85 91 49 85 58 44 75 29 59 60 1.05 97 55 1.67 96 1.06 1.39	21
uracy X)	55 49 44 44 59 97	-13
f accurac J(X)	65 45 65 65 1.07 1.42 2.14	-33
tors o	39 78 79 45 82 1.09	-40 -33 -13 21 52 63
indicators of accuracy of the mean of the gauge. $\mathbb{J}(\mathfrak{X})$	2300 39 65 2000 78 45 1700 79 65 1400 45 52 1100 82 1.07 800 1.09 1.47 500 1.47 2.14	
	Pressure (bars)	

Temperature (degrees Celsius)

Temperature (degree Celsius)

Temperature (degrees Celsius)

 Values underlined are those that exceed the standard criteria.
 Panel IV (SP/2) may authorise 4% for F for pressures above 4000 bars at temperatures below -30C°. Notes:

APPENDIX 5 to	ANNEX to	CHAPTER 1 of	<u>AEP-23</u>	
	1		RANGES AND LIMITS - FR	

									•						l	
STANDARD ACCEPTANCE CRITINGICATORS of precession (F) an of the mean (J) of the gauge. F/J	STANDARD ACCEPTANCE tors of precesion (Figera) of the gau	KCE CRITERIA 1 (F) and accuracy gauge.	curacy	Indica	GAUGE: FAN Indicators of precision of the gauge F(%)	GAUGE of pre F(%)	GAUGE: FAN if precision (X)	1 0 1	the ga	● 6nı	Indi	GAI cators of p	GAUGES: FAN Indicators of precision of the gauge $F(\mathcal{Z})$, 0 X G	the ga	9500
6500				-				1				-	4	Ę	5	36
	(2)		Pressure	2300	\$	20	8	22 25	8 2	S Pressure			1.03	3	3	3
Fressure	9	,	(hare)	0000	7.	34	2	54 66	58			_	1.71	21	13	7
(bars)	5/4	7/7	(6 180)	2	. K	2		55 55				_	1.24	6	18	20
4000				3 5	2 2	3 6					4	_	22	37	52	31
				3 5	3 5	3		. E			370	_	64	31	35	5 6
	į	Ş		3 8	: K		-		97 1.26		2900	_	55	22	37	53
	2/2	1/2		3	?	\$: 				220	_	7	88	\$	17
!											1700	_	75	38	54	7
200	-40	-30 +63			9	-33	-40 -33 -13 21 52	21 5	2 63	ļ.,			-13	-13 21	52	63
Temperature (degrees	re (degre	ees Celstus)			Temp	ratur	Temperature (degrees Celsius)	7885	Celst.	(SI		Temper	Temperature (degrees Celsius)	grees	<u>s</u>	tus)
				Indicators the gauge.	Indicators of accuracy of the mean of the gauge. $J(\mathcal{Z})$	f accura	uracy ()	of th	. Be 3	و د	Indi of t	Indicators of accur of the gauge. $J(\mathfrak{X})$	Indicators of accuracy of the mean of the gauge. $J(X)$	0 0	2 2	E
			Pressure (bars)	2300	45	25	58 83 84 1.05	83 .05	S 88	56 Press 61 (bars	Pressure 6500 (bars) 6000		2.99		84 1.61 1.15 47 66 23	1.15

Temperature (degree Celsius)

 Values underlined are those that exceed the standard criteria.
 Panel IV (SP/2) may authorise 4% for F for pressures above 4000 bars at temperatures below -30C*. Notes:

NATO UCLASSIFIED

8

5294.A

CHAPTER 2

CHARACTERISTICS OF EACH APPROVED TYPE

- 1. All approved crusher gauges must be described by the appropriate nation in accordance with the following guidelines.
- 2. Their characteristics are to be summarised in Annex of Chapter 1 and are also to be included in a NATO document, together with:
 - 2.1 Manufacturing nation, designation and date of approval.
 - 2.2 Specifications and a set of fully dimensioned manufacturing drawings, including assemblies where necessary, an overall drawing and a components list. It is important that the parallelism tolerance between the piston and anvil faces when assembled should be specified on the appropriate drawing and that the drawings of the anvil and piston guide should specify the required hardness values.
 - 2.3 Designation, form, dimensions and heat treatment (if required) of the crushers used.
 - 2.4 Method of calibrating crusher gauges or crushers.
 - 2.5 Description of firing tests carried out in accordance with Part IV of this publication; date and place of the firing and a complete report of the firings and test results.
 - 2.6 Pressure and temperature ranges for which the crusher gauge is approved.
 - 2.7 Temperature and pressure tarage tables.

AEP-23

- 10 -

PART II

INSTRUCTIONS FOR USE OF CRUSHER GAUGES

AEP-23

09/91

AEP-23

- 11 -

1. Preparation

It should be noted that a crusher gauge is, by design, a precision instrument and should be handled as such. Crusher gauges should be assembled in a clean room with a dust-free atmosphere, as foreign matter inside crusher gauges may cause deterioration or actual damage leading to obturation failures. New crusher gauges should be lightly coated with a suitable grease. After dismantling, all gauge components, in particular the piston and bore (piston guide), should be carefully cleaned. The piston should be handled only with clean suitable tools to avoid any contamination.

2. Dimensional checks

Components shall be measured in accordance with their respective specifications and manufacturing drawings. This procedure shall be fully described in the specification. Measurements must include piston and bore diameter and the parallelism between piston and anvil faces and must be within the specified tolerances.

Assembly

Crusher gauges shall be assembled in accordance with national instructions.

4. Dismantling and measurement

After use in firings the crusher gauge shall be carefuly dismantled and the remaining length of the crusher shall be measured in multiples of 10 microns or less with an instrument having a resolution better than 5 microns so that measurement error does not exceed 10 microns. The pressure shall then be read from the tarage table obtained in accordance with Part IV, Chapter 4, of this publication, at the crusher gauge firing temperature.

NOTE: The values in the tarage table apply only to the crusher lot used in the acceptance tests conducted in accordance with Part IV of this publication.

- 12 -

AEP-23

PART III

CRUSHER SPECIFICATIONS

AEP-23

09/91

1. Material

The purity of the raw material used for the crushers shall be specified and checked before manufacture.

2. Heat treatment

If a material requiring heat treatment is used for the crusher then the procedure shall be precisely specified and rigidly followed to minimise differences in crusher hardness.

3. Dimensional check

All dimensions must be within the specified tolerances.

Crushers shall be selected by national quality control methods. These methods must be submitted to Panel IV (Sub-Panel 2) for approval after examination by the Working Group of Experts (WGE.1).

4. Checking of batch homogeneity

The remaining length of a compressed crusher depends essentially on the following parameters:

- 1. actual dimensions;
- hardness (mechanical strength);
- level of load applied;
- 4. speed of application of the load.

Under given load conditions, dimensional and hardness homogeneity determines the reproducibility of compressive deformation of a new lot and hence the repeatability and accuracy of pressure measurements by crusher gauges.

The main factors affecting crusher homogeneity are:

- random and/or systematic changes in the crushers manufacturing process;
- differences in heat treatment (if applicable) from one batch to another.

By carrying out tests it is possible to determine the influence of these factors on pressure measurements and to remedy these shortcomings.

AEP-23

- 14 -

These tests fall into two groups: static tests and dynamic tests.

Static and/or dynamic tests must be carried out to evaluate the within and between batch homogeneity of the crushers.

4.1 Static test

The purpose of the static test is to evaluate crusher homogeneity. The procedure to be followed in this test will depend on national experience and preference. These procedures must be submitted to Panel IV (Sub-Panel 2) for approval after examination by the Working Group of Experts (WGE.1).

Statistical processing of the remaining length data will enable batches to be classified and static calibration tables to be drawn up if required.

4.2 Dynamic test

Dynamic testing using either a laboratory generator or a weapon may be used to examine the homogeneity of the crushers and where appropriate draw up dynamic calibration tables.

It may be used to group batches into a single lot or if this is not possible then to regroup batches into several lots.

Dynamic testing enables a more realistic comparison of batches to be made than is the case with static tests where the mechanical properties of the material are not fully taken into account. It is desirable that several applied load levels and temperatures are used in order to obtain comparison data over the full operating range of crusher.

The load-time profile of the dynamic generator should simulate as closely as possible a real weapon firing.

Statistical processing of the remaining lengths observed can be used:

- for grouping of batches;
- for drawing up dynamic calibration tables.

Static and/or dynamic tests must be conducted in accordance with any relevant national procedures. These procedures must be presented in the dossier supplied by each nation before the comparative firing trial for NATO approval.

- 15 -

AEP-23

PART IV

PROCEDURE FOR SUBMISSION OF CRUSHER GAUGES FOR NATO APPROVAL

AEP-23

09/91

CHAPTER 1

ACCEPTANCE PROCEDURE AND CRITERIA

1.1 To cover the pressure range from 500 to 6,500 bars and the temperature range from -40°C to +63°C a number of different types of crusher gauge may be required or alternatively the same gauge components may be used with different crushers.

If more than one crusher gauge design is required to cover the range 500 to 6,500 bars then an overlap of at least 600 bars between adjacent pressure ranges is necessary.

- 1.2 A country submitting one or more crusher gauges or crushers for approval shall provide:
 - 1.2.1 manufacturing drawings and specifications of the gauge components and its associated crusher for each type of crusher gauge;
 - documents describing the procedures for laboratory checking and static and dynamic testing of the crushers (paragraphs 3 and 4 of Part III of this publication);
 - 1.2.3 the results of the dynamic firing tests carried out for approval of the crusher gauges (Chapter 3 of Part IV of this publication);
 - 1.2.4 after a crusher gauge has been approved by NATO, the results relating to the new batches of crushers as required in Part V of this publication.
- 1.3 The data shall be presented in the form of an Annex to the report giving the results of the dynamic firing tests. The results shall be analysed in accordance with the method indicated in Chapter 4 of Part IV of this publication. Any deviation from the acceptance criteria shall be indicated. AC/225(Panel IV/Sub-Panel 2) shall examine the approval request and shall have the right to grant, in the case of minor deviations, concessions from the criteria laid down (F, J).

- 17 -

AEP-23

CHAPTER 2

DEFINITION OF TERMS RELATING TO QUALITY OF MEASUREMENTS

- 2.1 Certain terms are used in the discussion of these tests and in the analysis of the test results. It is important that the definitions of these terms be clearly understood. They are as follows:
- 2.2 "The true pressure" is that value of maximum gas pressure which actually exists and would be measured by an ideal system. For present purposes, modern electrical sensors which record pressure as a function of time are considered to give the best possible estimation of "true pressure".
- 2.3 The "accuracy of the mean" of a pressure gauge is its ability to record or measure the "true pressure" without systematic error. It may depend on pressure level, temperature or both. Any systematic error due to the electrical gauges will result in an indeterminate error in the crusher pressures indicated in the tarage table.
- 2.4 The "precision" of a measuring instrument is its ability to give, under specified conditions of use, very similar readings on repeated application of a single input value at indeterminate time intervals. It indicates both the regularity and stability of the result given by a gauge and also the uniformity of data supplied by several gauges of the same type. In this case it is referred to as reproducibility.
- 2.5 The "reliability" of a sensor is a good indicator of its quality. During testing, it is determined by taking the ratio of the number of correct measurements supplied by the gauge to the number of measurements planned.

- 18 -

AEP-23

CHAPTER 3

DYNAMIC FIRING TESTS OF CRUSHER GAUGES

3.1 A crusher gauge submitted for NATO approval must have first undergone the dynamic firing tests described below. The following information shall be recorded during these tests: guns and ammunition used; time and place of firing; detailed description of the pressure time measurement system; the pressure time curves showing the absence of unacceptable pressure waves or ignition irregularities which might influence crusher gauge response; full details of all the remaining lengths and "true pressures" measured; the examination and analysis of the results in accordance with this Annex, for establishment of the tarage tables for pressure and temperature, as well as results for accuracy of mean, precision and reliability.

Every effort must be made to ensure that the crusher gauges do not move during firing. If crusher gauges move within or beyond the chamber, their recovered positions shall be recorded after the firing.

- 3.2 Two electrical pressure measuring systems, operating independently of one another and if possible using gauges based on different physical principles, shall be used to record chamber pressure-time history. The measuring systems shall have a frequency response from DC to 20kHz at at least 3dB. The gauges shall be located in the chamber in such a way that their expected signals are highly comparable, i.e. at the same distance from the breech face. If the difference between the two maximum pressure readings for a single round does not exceed 2% of their mean, this mean value shall be taken as the "true pressure". Otherwise, the data from the round shall be discounted and the round repeated.
- 3.3 It is essential that the crusher gauges and electrical gauges are located within the same section of the chamber in order to minimise error due to pressure gradient. The crusher gauges shall be orientated with their sensitive ends facing the muzzle and their sensitive axes parallel to the gun axis. The sensitive ends of the crusher gauges shall be located to within ± 25 mm of the plane containing the sensitive faces or axes (depending on orientation) of the electrical gauges.
- 3.4 To provide basic data for production of the tarage table, each crusher gauge shall be subjected to firings over a measurement range compatible with its design table.

AEP-23

- 19 -

All remaining lengths shall be measured with an instrument with such characteristics and resolution as to ensure a maximum uncertainty not exceeding ± 5 microns.

The pressure levels shall be at approximately 300 bar intervals up to 2,300 bars (LP crusher gauges) and approximately 700 bar intervals above 2,300 bars (HP crusher gauges). There shall be at least seven levels in the low pressure range and at least eight in the high pressure range.

If it proves necessary to conduct tests on a single crusher gauge in two different weapons, the pressure ranges covered by the weapons shall overlap by at least two pressure levels. The pressure limits may be adjusted according to circumstances subject to the agreement of Panel IV (Sub-Panel 2).

If a third type of crusher gauge is submitted by a single country the pressure ranges and levels for the test shall be decided by Panel IV (Sub-Panel 2).

3.5 As discussed in paragraph 3.2 of Part IV of this publication at least two electrical gauges shall be used for each firing. However if the weapon system is expected to produce large pressure gradients and if the crusher gauges cannot be prevented from moving during the firing then consideration should be given to installing a third electrical gauge within the chamber. The location of the third electrical gauge and the allowances to be made for pressure gradient shall be submitted to Panel IV (Sub-Panel 2) through the Working Group of Experts (WGE.1) for approval prior to the test.

Crusher gauges shall be used in groups of 5 for each type fired in the round, so for a weapon system that can accommodate a total of 15 gauges 3 different types may be fired per round.

For each pressure/temperature parameter pair, the number of firings carried out shall be such that 15 measurements are available for each type.

If 15 crusher gauges cannot be installed in the chamber of the weapon used (for reasons of space), the problem shall be re-examined by the Working Group of Experts (WGE.1) and recommendations submitted to Panel IV (Sub-Panel 2) for approval.

3.6 Each day's firing shall begin with a freshly calibrated set of electrical gauges. The gauges shall be recalibrated after a maximum of 20 rounds fired. Calibration shall be carried out on a test bench in accordance with the organizing country's method and if possible in the adaptors used for the firings.

The calibration relationship for the electrical gauge must be used in order to calculate pressure.

3.7 In order to produce a tarage table for pressure in terms of remaining length and temperature, firings shall be carried out with the crusher gauges conditioned at -40°C, -33°C, -13°C, +21°C, +52°C, +63°C and any other temperature decided by Panel IV (Sub-Panel 2). These temperatures must be maintained to within +2°C after a conditioning time of 24 hours.

The tables shall be drawn at 50 micron intervals for the remaining length and at 5°C intervals for the temperatures, to which special values may be added, in particular the firing temperatures must be included.

- 21 -

CHAPTER 4

ANALYSIS OF RESULTS

4.1 General

It should be noted in the following analysis that although pressure is the independent variable for ease of analysis the remaining length has been taken as the independent variable. This is a reasonable assumption as the pressure generated by the gun leads to both piezo electric pressure and remaining length.

The statistical analysis described below assumes that there are at least two remaining length measurements available for each crusher gauge type after the firing (after elimination of defective measurements, e.g. resulting from gas leaks etc.). A firing for which only one value remains for a crusher gauge type shall be discounted for that crusher gauge type.

Each system shall be analysed separately.

4.2 Notation

Generic symbols

- temperature in °C;
- P pressure in bars;
- L remaining length of the crusher in microns;
- g(L) regression function: pressure as a function of remaining length at constant temperature;
- h'(θ) regression function: pressure as a function of temperature at constant remaining length;
- h"(P) regression function: temperature as a function of pressure at constant remaining length;
- a,B, r coefficients of function g;
- u,v,w coefficients of function h;

<u>AEP-23</u>

- 22 -

σ . regression standard deviation estimator;

n.d.f. number of degrees of freedom of an estimator.

Indices	and notation	Where first used
i	repetition test index for a given (0,P) for the system being analysed	(1)
NI	number of repetition tests for the system under analysis for a given (θ,P)	(1)
t	experiment plan temperature index	(2)
NT	number of temperatures in the experiment plan	(2)
j	pressure level index number at each temperature in the experiment plan	(3)
NP	theoretical (i.e. planned) number of pressure levels per temperature in the experiment plan and per test	(3)
NP _{t1}	number of pressure levels attained for temperature θ_{t} , during test i	(6)
k	index number of the remaining length measurement at a point (0,P) of the experiment plan, for test i	(5)
M	theoretical (i.e. planned) number of remaining length measurements at each planned point (0,P) in the experiment plan per test	(5)
M'tij	number of remaining length measurements made at a point achieved in the experiment plan (θ_t, P^r_{tij}) , after elimination of defective measurements, for test i	(7)

	- 23 -	<u>AEP-23</u>
M"tij	as above, after elimination of defective measurements and outliers, for test i	(15)
r	tarage table temperature index	(34)
NR	number of temperatures in the tarage table	(34)
S	tarage table remaining length index	(18)
NS	number of remaining lengths in the tarage table	(18)
Planned,	achieved and measured values	Where first used
θt	value of the tth temperature in the experiment plan	(2)
P*j	value of the jth theoretical (i.e. planned) pressure in the experiment plan	(45)
Ptij	value of the jth pressure achieved for temperature 9 _t , during test 1 ("true pressure")	(4)
PPtij	mean of the two values measured by the piezo-electric gauges, estimating the achieved pressure Ptij	(4)
d'tij	uncertainty on P _{tij} due to the accuracy of the measurements leading to P ^p tij (by piezo-electric gauges)	(12)
Ltijk	value of the kth remaining length measurement at point (O _t ,P _{tij}), from the kth crusher	(5)
ī _{tij}	corresponding mean value	(20)
θr	value of the rth temperature in the tarage table	(35)

AEP-23

- 24 -

Ls	value of the sth remaining length in the tarage table	(19)
Calculat	ed and estimated values	Where first used
Ptijk	pressure estimated by the regression function g(L) for the kth length measurement Ltijk at point (0t, Ptij)	(10)
^{фт} tijk	pressure estimated by the tarage table for the kth length measurement Ltijk at point (0t, Ptij)	
P ^T tij	corresponding mean pressure at point $(\theta_t, P_{t j})$	(38)
E't1	quadratic error to be minimised for regression from the available measurements (excluding defective measurements) at temperature	
	θ _t , in test i	(11)
9'ti	associated regression function	(8)
σti	associated standard deviation of regression	(13)
E"ti	quadratic error to be minimised for regression from the measurements selected (excluding defective measurements and outliers at temperature θ_t , during test i	s) . (17)
9"ti	associated regression function	(17)
P ^C ts1	calculated pressure at each point (θ_t, L_s) for the temperatures θ_t in the experiment plan and the remaining lengths L_s in the tarage table, in test i	(19)
Ptsi	corresponding estimated pressure at point (θ_t, L_s) , in test i	(26)

	- 25 -	<u>AEP-23</u>
^{y2} tsi	weighting coefficient for minimising of E's1 and E"s1	(23)
E'si	quadratic error to be minimised for direct regression at length L_{S} , during test i	(27)
EN's1	associated standardized quadratic error	(28)
h¹si	associated regression function	(24)
θ̂t	estimator of θ_t during minimisation of E^*_{s1}	(31)
E"si	quadratic error to be minimised for inverse regression at length L_S , in test i	(32)
EN"si	associated standardized quadratic error	(33)
h"si	associated regression function	(29)
Prsi	calculated pressure at each point (θ_Γ, L_S) in the tarage table, in test i	(35)
Prs	corresponding mean pressure at point (θ_r, L_s)	(43)
(P̃rs)	matrix of the values of Prs constituting the tarage table for the system analysed	(44)
Perform	ance indicators	Where first used
J ₁ (0,P)	gauge accuracy indicator value at a point (0,P) in test i	(37)
J(0,P)	as above, for all tests	(49)
F ₁ (0,P)	gauge repeatability indicator value at a point (0,P) in test i	(38)
F(0,P)	as above, for all tests	(50)

AEP-23	- 26 <i>-</i>		
	Q ₁ (0,P) value of the first gauge quality indicator at a point (0,P): reliability of the gauge as indicated by defective measurements alone	(51)	
	Q2(0,P) value of the second gauge quality indicator at a point (0,P): percentage of correct operation of the gauge, i.e. the reliability as indicated by all the values eliminated (after elimination of defective measurements and outliers	(52)	
	Q ₃ (0,P) value of the third gauge quality indicator at a point (0,P): reliability as indicated by the outliers	(53)	
	4.3 Analysis of the system under consideration		
	Analysis is in two stages:		
	- analysis for each test i in the system:		
	1 <u><</u> 1 <u><</u> NI		(1)
	- "global" analysis for all the NI tests.		
	4.3.1 Analysis of test number i of the system		
	4.3.1.1 Analysis per temperature θ _t in the experiment plan:		
	For each temperature θ_t , $1 \le t \le NT$ carry out operations 4.3.1.1.1 to 4.3.1.1.4 below:		(2)
	4.3.1.1.1 <u>Calibration of the regression</u> functions at temperature θ_{t} :		

(a) Measurements carried out

NATO UNCLASSIFIED

(3)

For each firing at a pressure level j, i \leq j \leq NP

- 27 -AEP-23 - pressure measurements from the two piezo-electric gauges; the mean of the two values is an estimate of the "true pressure": (4) Ptij = P tij - measurement of M remaining length values on the M crushers to be calibrated (5) Ltijk, $1 \le k \le M$ (b) Data selected: - as some pressures will be mission, only NPt1 firings at temperature 0t will be available: (6) 1 < j < NPt1 < NP - after elimination of the defective measurements, M'_{tij} remaining length values at point (8t, $\text{PP}_{\text{tij}})$ are selected: (7) 1 ≤ k ≤ M¹tij ≤ M ... (c) Adjustment by "exponential regression": - regression model: P_{tij} - $g'_{ti}(L_{tijk})$ + "residual error" where (8) (9) $g'_{ti}(L) = \gamma'_{ti} + \beta'_{ti}.exp (\alpha'_{ti}.L)$

 $\alpha'_{ti}.L + \beta'_{ti} (\gamma'_{ti}=0)$

AEP-23

- 28 -

- associated estimation:

$$P_{\text{tijk}} = g'_{\text{ti}} (L_{\text{tijk}})$$
) (10)

 regression by minimizing, under the constraint < 'ti ≤ 0, the "quadratic error":

$$E'_{ti} = \frac{\sum_{j=1}^{N} \frac{P_{ti}}{\sum_{k=1}^{N} \frac{P_{tijk} - P^{p}_{tij}}{\sigma'_{tij}}}^{2} (11)$$

where

$$\sigma_{\text{tij}}^{i} = 1\%.P^{0}_{\text{tij}} \tag{12}$$

is an estimate of the measurement error on the pressures supplied by the piezo-electric gauges, (minimisation is carried out in relation to parameters &'ti, B'ti, and Y'ti)

- exponential regression: use the estimates of Ptijk supplied by the exponential function g't1
- if

|a'ti| ≤ 2.10-3

linear regression: use the estimates corresponding to the linear form of $g't_1$ (with $\gamma't_1=0$)

- 29 -

AEP-23

regression residual standard deviation:

 $\sigma_{ti} = (E'_{ti} \text{ (minimum)/n.d.f})^{\frac{1}{2}}$ where the number of degrees of freedom of the regression is given by:

n.d.f. =
$$\begin{bmatrix} \frac{NP_{ti}}{\sum} & \\ \frac{1}{i-1} & \\ M'_{tij} \end{bmatrix} - 3$$
 (14)

OL

n.d.f. =
$$\begin{bmatrix} \frac{NP_{ti}}{\sum_{i=1}^{NP_{ti}}} & H'_{tij} \end{bmatrix} - 2 \text{ for the linear case}$$

where the sum represents the total number of measurements carried out and not defective (for temperature θ_t).

4.3.1.1.2 Processing of outliers at temperature θ_t :

- (a) Determination of outliers from the Tietjen-Moore method, in the following variant:
 - double determination of the number of outliers by the "greatest deviation" and "second greatest deviation" procedure;
 - determination of the outliers from the table corresponding to the type I risk 5%.

AEP-23

- 30 -

(b) Elimination of outliers:

- elimination of the values of measurements detected by the test in (a) above;
- after this elimination, we have M''tij remaining length values at point (8t, Potij):

 $1 \le k \le M''t_{1j} \le M't_{1j} \le M$

(15)

- (c) Coherency of the two high pressure regression functions in the overlap region:
 - perform a linear regression on the M''tij measurements in the overlap region (θ_t, P^otij) corresponding to the first weapon, then a similar linear regression for the second weapon;
 - estimate the quality of the overlap by comparing the two regression straight lines from the t tests giving the corresponding type I risk.

4.3.1.1.3 Gorrected regression functions at temperature θ_t :

(a) Available data:

- for the NPti firing at temperature
 9t (4.3.1.1.1.b);
- after elimination of outliers
 (4.3.1.1.2.b);
- we have M''tij remaining length values at each point (θt, P^otij).

- 31 -

AEP-23

(b) If outliers have been eliminated, i.e. if:

$$\frac{NP_{ti}}{\sqrt{\frac{1}{j-1}}} \quad M''_{tij} \leftarrow \frac{NP_{ti}}{\sqrt{\frac{1}{j-1}}} \quad M'_{tij} \qquad (16)$$

(the number of valid measurements at temperature θ_t has diminished), perform the regression stage in Cabelow; otherwise keep function g^*t_1 identical to g^tt_1

(i.e. α' 'ti = α' ti, β' 'ti = β' ti, γ' 'ti = γ' ti), and move on to 4.3.1.1.4.

(c) Adjustment by exponential regression:

Use the model in 4.3.1.1.1.c with M''tij measurements at (θ_t, P_{tij}) instead of M'tij, giving a function:

$$g''_{ti}(L) = \gamma''_{ti} + \beta''_{ti}.exp(\alpha''_{ti}.L)$$
 (17)

or

$$\alpha''_{ti}.L + \beta''_{ti} (\gamma''_{ti}=0)$$

obtaining by minimising E''ti with $|\alpha''t_i| \leq 2.10^{-3}$

4.3.1.1.4 Discretisation of the curves P = g''ti(L):

Calculation of the pressure for each length in the tarage table:

for
$$1 < s < NS$$
 (18)

perform
$$P^{C}_{tsi} = g''_{ti}(L_s)$$
 (19)

4.3.1.2 Correction of each length Ls in the tarage table for temperature:

For each length L_s , $1 \le s \le NS$

Perform operations 4.3.1.2.1 to 4.3.1.2.3 below.

AEP-23

- 32 -

4.3.1.2.1 Regression functions at length Ls:

- (a) Available data:
 - for the NT temperatures θ_t in the experiment plan;
 - the pressures P^Ctsi interpolated from the exponential curves;
 - p = g''+1(L)(cf. 4.3.1.1.4);
 - the M''tij lengths Ltijk for j = j', j'' such that the mean lengths Ltij' and Ltij'' bracket Ls:

$$\bar{L}_{tij}' \leq L_s \leq \bar{L}_{tij}''$$
 (20)

(see calculation of mean lengths in (b) below).

- (b) Calculation of weighting coefficients:
 - for j = j', j'', calculation of the standardized variance

$$v^{2}_{tij} = \frac{1}{H''_{tij} - 1} \quad \frac{\prod_{k=1}^{H''_{tij}} \left[\frac{L_{tijk} - \tilde{L}_{tij}}{\tilde{L}_{tij}} \right]^{2}}{\left[\frac{\tilde{L}_{tijk} - \tilde{L}_{tij}}{\tilde{L}_{tij}} \right]^{2}}$$
(21)

in which mean length is given by

$$\hat{L}_{tij} = \frac{1}{H''_{tij}} \sum_{k=1}^{H''_{tij}} L_{tijk}$$
 (22)

any zero values of V^2 tij will be replaced by the value of the V^2 tij corresponding to the resolution of the measurement tools used at the time of the NATO comparative trial;

- 33 - AEP-23

- linear interpolation in L (or in P)
between j' and j'': e.g.:

$$v^2_{tsi} = v^2_{tij}' + (v^2_{tij}'' - v^2_{tij}') \frac{L_s - \bar{L}_{tij}'}{\bar{L}_{tij}'' - \bar{L}_{tij}'}$$
 (23)

any zero values of V^2_{ts1} will be replaced by the value of the V^2_{ts1} corresponding to the resolution of the measurement tools used at the time of the NATO comparative trails.

(c) Adjustment of parabolic regression:

Case 1:

- direct regression model:

$$P_{tsi} = h'_{si} (\theta_t) + "residual error" (24)$$

where

$$h'_{si}(\theta) = u'_{si} + V'_{si} \cdot \theta + w'_{si} \cdot \theta^2$$
 (25)

- associated estimation

$$\hat{P}_{tsi} = h'_{si}(\theta_t) \tag{26}$$

- regression by minimising the quadratic error:

$$\mathbf{E'} = \frac{\frac{NT}{\sqrt{\mathbf{P}_{tsi}}} - \mathbf{P^c_{tsi}}^2}{\frac{f_{tsi}}{\sqrt{\mathbf{P}_{tsi}}}}$$
(27)

under constraint of monotony and convexity: for any θ , $w'_{s1} \ge 0$

$$Dh'_{Si}(\theta) = v'_{Si} + 2w'_{Si} \cdot \theta \leq 0$$

(D = derivative)

(minimisation is carried out in relation to parameters u's; v's; w's;)

AEP-23

- 34 -

 calculation of the standardized quadratic error:

$$EN'_{si} = \frac{NT}{t-1} \left[\frac{\underset{pc}{A} - p^{c}}{\underset{pc}{v}_{si}} \right]^{2}$$
 (28)

Case 2:

- inverse regression model

$$\theta_t = h^{11}si (P^ctsi) + "residual error" (29)$$

where

$$h''_{si}(P) = u''_{si} + v''_{si}P + w''_{si}P^2$$
 (30)

- associated estimation:

$$\hat{\theta}_{t} = h^{\prime\prime}_{si}(pc_{tsi}) \tag{31}$$

regression by minimisation of the quadratic error:

$$E''_{si} = \frac{NT}{\sum_{t=1}^{T} \left[\frac{(\hat{\theta}_t - \theta_t)^2}{v^2_{tsi}} \right]}$$
 (32)

under constraint of monotony and convexity: for any P, w''s ≥ 0

(D = derivative)

(minimisation is carried out in relation to parameters u''si, V''si, W''si)

calculation of the standardized quadratic error:

$$EN''_{si} = \frac{NT}{r - 1} \left[\frac{\theta_t - \theta_t}{\theta_t} \right]^2$$
 (33)

NATO UNCLASSIFIED

- 35 -

AEP-23

Choice of the model

- by comparison of the standardized errors:
- if EN'si ≤ EN''si, select case 1; otherwise select case 2.

4.3.1.2.2 Construction of tarage table for test i

Calculation of the pressure for each temperature in the tarage table:

for
$$1 \le r \le NR$$
 (34)

if case 1 has been selected:

perform
$$P_{rsi} = h'_{si} (\theta_r)$$
 (35)

otherwise (i.e. if case 2 has been selected) solve equation
$$h''(P_{rsi}) = \theta_r$$
 (36)

(Prsi is the smallest root).

4.3.1.2.3 Performance of the crusher gauge for test i

- (a) Definition of the performance criteria associated with the accuracy of the crusher gauge:
 - performance indicators of the gauge's accuracy of the mean

at a point (θ_t, P_{tij}) in the plan

$$J_{i}(\theta_{t}, P^{\rho}_{tij}) = \begin{bmatrix} \frac{H'_{tij}}{1} & AT & P^{\rho}_{tij} \\ \frac{1}{H''_{tij}} & \frac{AT}{k=1} & P^{\rho}_{tij} \end{bmatrix}^{2} . 100% (37)$$

where β^T tijk) is the kth pressure estimated from the kth length L_{tijk} at this point, calculated by linear interpolation from the tarage table (P_{rsi}) (cf. (b) below);

AEP-23

- 36 -

 crusher gauge repeatability performance indicators: with the same notation,

$$F_{i}(\theta_{t},P^{\rho}_{tij}) = \begin{bmatrix} \frac{H''_{tij}}{1} & AT & T \\ \frac{1}{M''_{tij}-1} & \frac{1}{k-1} & P_{tij} \\ \hline \frac{\hat{p}_{tij}^{T}}{\hat{p}_{tij}^{T}} \end{bmatrix}^{2} . 100%$$
(38)

where P^T_{tij} is the mean pressure estimated by means of the tarage table, at point (θ_t , P^P_{tij}) (cf. b.).

(b) Calculation of estimated pressure at point $(\theta_{\downarrow}, P^{\rho}_{\downarrow \downarrow \downarrow})$:

 finding of the temperature index r from the tarage table such that

$$\theta_{\Gamma} = \theta_{t}$$
 (of the point under consideration) (39)

- bracketing of each length L_{tijk} , for $1 \le k \le M''_{tij}$, by tarage lengths L_s' and L_s'' :

$$L_{s}' \leq L_{tijk} \leq L_{s}''$$
 (40)

 calculation of each estimated pressure pT_{tijk} (1 ≤ k ≤ M''tij) by linear interpolation from the pressures in the tarage table:

$$\hat{P}_{tijk}^{T} = P_{rs'i} + (P_{rs'i} - P_{rs'i}) \frac{L_{tijk} - L_{s'}}{L_{s'i} - L_{s'}}$$
 (41),

 calculation of the corresponding mean pressure:

$$\bar{p}_{\text{tij}}^{\mathsf{T}} = \frac{1}{\mathsf{H}''_{\text{tij}}} \sum_{k=1}^{\mathsf{M}''_{\text{tijk}}} \bar{p}_{\text{tijk}}^{\mathsf{T}} \tag{42}$$

- 37 - AEP-23

4.3.2 Analysis of all the tests of the system

4.3.2.1 Calculation of the tarage table for the system analysed:

From the NI tarage tables (P_{rs1}) for each test i, average the estimated pressure values:

for $1 \le r \le NR$, $1 \le s \le NS$

calculate

$$\tilde{P}_{rs} = \frac{1}{NI} \sum_{i=1}^{NI} P_{rsi}$$
 (43)

which gives the definitive tarage table

$$(\overline{P}_{\Gamma S})$$
 $1 \le \Gamma \le NR$, $1 \le S \le NS$ (44)

4.3.2.2 Crusher gauge performance (for all tests):

4.3.2.2.1 Performance criteria associated with the accuracy of the crusher gauge:

(a) Available values:

- the temperature in the plan:

$$(\theta_t)$$
, $1 \le t \le NT$

- the planned pressures:

$$(P*_{j}), 1 \leq j \leq NP \tag{45}$$

- the pressures achieved during each test i:

$$\begin{array}{l} (\mathsf{PP}_{\mbox{tij}}), \ 1 \leq t \leq \mathsf{NT}, \ 1 \leq j \leq \mathsf{NP}_{\mbox{ti}}, \\ 1 \leq i \leq \mathsf{NI} \end{array}$$

the corresponding performance indicators:

$$J_i(\theta_t, P^{\rho}_{tij})$$
 and $F_i(\theta_t, P^{\rho}_{tij})$

AEP-23

- 38 -

(b) Pressure standardization:

- for each test i, 1 ≤ i ≤ NI, for each temperature θ_t, 1 ≤ t ≤ NT;
- calculate J₁ (θ_t,P*_j) and F₁(θ_t,P*_j) by linear interpolation, for 1 ≤ j ≤ NP:

$$\mathtt{J}_{\mathtt{i}}(\boldsymbol{\theta}_{\mathtt{t}}, \mathtt{P^*}_{\mathtt{j}}) = \mathtt{J}_{\mathtt{i}}(\boldsymbol{\theta}_{\mathtt{t}}, \mathtt{P^{\rho}_{\mathtt{tij}}},) + (\mathtt{J}_{\mathtt{i}}(\boldsymbol{\theta}_{\mathtt{t}}, \mathtt{P^{\rho}_{\mathtt{tij}}},) - \mathtt{J}_{\mathtt{i}}(\boldsymbol{\theta}_{\mathtt{t}}, \mathtt{P^{\rho}_{\mathtt{tij}}},)) \times$$

$$\left[\frac{p^*_{j} - p^{\rho}_{tij'}}{p^{\rho}_{tij'} - p^{\rho}_{tij'}}\right]$$
(46)

$$F_i(\theta_t, P^*_j) = F_i(\theta_t, P^{\rho}_{tij}) + (F_i(\theta_t, P^{\rho}_{tij})) -$$

$$F_{i}(\theta_{t},P^{\rho}_{tij},)) \times \left[\frac{P^{\alpha}_{j}-P^{\rho}_{tij}}{P^{\rho}_{tij},P^{\rho}_{tij}}\right]$$
(47)

where j' and j'' are indexed such that PPtij' and PPtij' bracket P*j:

$$P^{\rho}_{tij'} \leq P^{\star}_{j} \leq P^{\rho}_{tij''} \tag{48}$$

(c) Performance indicators for all tests:

- mean squared J₁:

for $1 \le t \le NT$, $1 \le j \le NP$

calculate
$$J(\theta_t, P^*_j) = \left[\frac{1}{NI} \sum_{i=1}^{NI} J_i^2(\theta_t, P^*_j)\right]^{N}$$
 (49)

in general J must not exceed 2%, except that for pressures above 4000 bars occurring at temperatures below -30°C when J must not exceed 4%;

- 39 -

AEP-23

- mean square F₁:

for
$$1 \le t \le NT$$
, $1 \le j \le NP$ calculate

$$\mathbf{F}(\mathbf{\theta_t}, \mathbf{P^*_j}) = \begin{bmatrix} \frac{\mathbf{NI}}{\mathbf{NI}} & \mathbf{F_i} & (\mathbf{\theta_t}, \mathbf{P^*_j}) \end{bmatrix}^2$$
(50)

in general F must not exceed 1%, except that for pressures above 4000 bars or at temperatures below -30°C when F must not exceed 2%; 4% may be allowed by Panel IV (Sub-Panel 2) for pressures above 4000 bars occurring at temperatures below -30°C.

4.3.2.2.2 Crusher gauge quality performance criteria:

(a) Available values:

- the temperatures in the plan:

$$(\theta_t)$$
, $1 \le t \le NT$

- the planned pressures:

$$(P*_{j}), 1 \leq j \leq NP$$

- the numbers of remaining length measurements at each point (θ_t, P^p_{tij}) , in each test i:

$$\begin{array}{l} \text{M'tij and M''tij'} \ 1 \le t \le \text{NT,} \\ 1 \le \text{J} \le \text{NPt1,} \ 1 \le \text{i} \le \text{NI} \end{array}$$

(b) <u>Definition and calculation of crusher</u> gauge quality indicators:

reliability as indicated by defective measurements alone:

$$Q_{1}(\theta_{t},P_{j}^{*}) = \frac{NI}{\sqrt{\frac{1}{I-1}}} H'_{tij}/(NI.M)$$
 (51)

NATO UNCLASSIFIED

AEP-23

- 40 -

 reliability as indicated by defective measurements and outliers:

$$Q_2(\theta_t, P_j^*) = \frac{NI}{\sum_{i=1}^{j}} H''_{tij}'(NI.H)$$
 (52)

 reliability as indicated by outliers alone:

$$Q_{3}(\theta_{t},P^{*}_{j}) = \begin{bmatrix} \frac{NI}{2} & H''_{tij} \end{bmatrix} / \begin{bmatrix} \frac{NI}{2} & H'_{tij} \end{bmatrix}$$
(53)

4.3.2.3 Use of the tarage table for the system analysed:

From a measured pair (0,L), the pressure P is estimated by double linear interpolation (length, then temperature), as follows:

- finding of the indices r' and r'' (between 1 and NR) such that:

$$\theta_{\Gamma}, \leq \theta \leq \theta_{\Gamma^{11}}$$
 (54)

- finding of the indices s' and s'' (between 1 and NS) such that:

$$L_{S'} \leq L \leq L_{S''} \tag{55}$$

 the pair (θ,L) has been bracketed by a quadrilateral of apices (θ_r: L_s:),

$$(\theta_{\Gamma'}, L_{S'}), (\theta_{\Gamma'}, L_{S'}), (\theta_{\Gamma'}, L_{S'})$$
:

we therefore know the 4 pressures from the tarage table corresponding to the apices, i.e. Prisi'Prisi', Prisi'Prisi'

- linear interpolation in L at temperature

$$P_{r'L} = \bar{P}_{r's}, + (\bar{P}_{r's'}, -\bar{P}_{r's'}) \frac{L - L_{s'}}{L_{s'} - L_{s'}}$$
 (56)

- 41 - AEP-23

- linear interpolation in L at temperature θ_{ref} :

$$P_{T^{1+}L} = \tilde{P}_{T^{1+}g}, + (\tilde{P}_{T^{1+}g}, -\tilde{P}_{T^{1+}g},) \frac{L - L_{g}}{L_{g+} - L_{g}}$$
(57)

- linear interpolation in 8 at length L:

$$P_{\Theta L} = P_{r'L} + (P_{r''L} - P_{r'L}) \frac{\Theta - \Theta_{r'}}{\Theta_{r''} - \Theta_{r'}}$$
 (58)

The estimated value of the unknown pressure P is taken to be the value P_{OL} thus calculated.

- 42 -

AEP-23

PART V

APPROVAL OF CRUSHER GAUGES

AEP-23

09/91

NATO UNCLASSIFIED

- 43 -

AEP-23

1. The comparative tests defined in Part IV of this publication for submission of crusher gauges for approval shall be carried out in accordance with this publication at approximately five-year intervals, on a date and in a place determined by AC/225(Panel IV/Sub-Panel 2).

The firing tests shall not be carried out twice in succession in one country.

- 2. Any country must notify Panel IV (Sub-Panel 2) of its intention to submit a crusher gauge for NATO approval. If it intends to carry out its own firings (in accordance with Part IV of this publication), the firings must be carried out in conjunction with another crusher gauge already approved. The Panel shall take the necessary steps to ensure that another country supplies enough crusher gauges of a previously approved type for use during the firings.
- 3. If, following approval of a crusher gauge by NATO, a new lot of crushers is to be brought into service, the new lot must be compared with the previously approved lot by an appropriate dynamic test method.

The method, the results of these tests and the tests described in Part III of this publication shall be submitted to Panel IV (Sub-Panel 2) for approval.